



SOUTHERN CALIFORNIA PUBLIC POWER AUTHORITY
1160 NICOLE COURT
GLENORA, CA 91740
(626) 793-9364 – FAX: (626) 793-9461
www.scppa.org

ANAHEIM • AZUSA • BANNING • BURBANK • CERRITOS
COLTON • GLENDALE • LOS ANGELES • PASADENA
RIVERSIDE • VERNON • IMPERIAL IRRIGATION DISTRICT

Frequently Asked Questions (FAQ)
RFP for Engineering Services: Landfill Gas Processing
January 22, 2014

1. Q: Who is the contracting entity – SCPPA or City of Glendale?
A: SCPPA
2. Q: Is a sample Professional Services Agreement (PSA) available?
A: Yes, we have a template PSA, but we do not release it until a Respondent has been selected for further negotiations and contracting of services.
3. Q: Are typical gas productions quantities and composition information available?
A: Yes, the gas delivered to the Grayson Plant is in the range of 6500 – 7000 SCFM. The composition information can be found on the website as an attachment, “Landfill Gas Analysis”.
4. Q: What level of design detail is expected at the completion of Phase II?
For example, is this a 30, 60, or 90% design?
A: The expected level of design detail is 90% by the end of Phase II.
5. Q: Will the design package developed in Phase II be used in future EPC solicitation?
If so, would the contractor completing Phase II be eligible to bid on the EPC work?
A: Yes, the design package developed in Phase II will be used in future EPC solicitation and a contractor will be eligible to bid on the EPC work.
6. Q: Are the SBE and DVBE targets mandatory for teams responding to this RFP? Must viable partners be identified as part of the RFP submission?
A: In the RFP, Section VII.7, Supplier Diversity, we ask that “Respondents take reasonable steps ...” in meeting this requirement to find and identify viable partners as part of the RFP submission.
7. Q: It is our understanding that the City of Glendale recently completed a study evaluating alternatives for the future of Grayson. Is that study available to the potential Respondents?
A: The most recent study of repowering options was conducted in early 2012, and was not a complete study of all feasible options. Since 2011, Glendale has decided to adopt a phased approach to studying repowering options, starting with the LFG clean-up analysis that is the subject of this RFP.)